



LIQUEFIED PETROLEUM GAS PRE-INSTALLATION CHECKLIST
OFFICE OF ATTORNEY GENERAL
NORTH DAKOTA STATE FIRE MARSHAL
SFN 52040 (7-02)

The intent of this checklist is to assist in ensuring the safety of the owner and of the public. Within North Dakota the storage, handling, and use of LP-Gas is governed by the standards of the National Fire Protection Association (NFPA). The following, when completed, will assist the Fire Marshal's Office in obtaining a better understanding of the installation. In no way should this checklist be substituted in place of NFPA pamphlet 58. All installations must comply with any local requirements and NFPA standard 58.

LOCATION OF INSTALLATION

Company/Owner Name	
Site Address	
City	County
Mailing Address	Zip
	Phone

INSTALLER INFORMATION

Company Name	
Mailing Address	
City/State	Zip
	Phone

INSTALLATION INFORMATION

Number of tanks to be installed aboveground:
Number of tanks to be installed underground:
Number of tanks to be installed mounded:
Planned date of installation:

Please complete table:

	Tank 1	Tank 2	Tank 3	Tank 4	Tank 5
Manufacturer					
Year					
Water Capacity					
Design Pressure					
Vertical distance from top of container to relief valve discharge					
Number Relief Valves					
Relief Valve Capacity					
DISTANCE TO:					
Nearest Building					
Nearest LP Container					
Adjoining property line which is or may be built upon					
Nearest flammable or combustible liquid aboveground fuel tank					

Please provide a copy of this checklist to the local fire officials for review or approval.

Please circle either "Yes" or "No" as appropriate:		
Yes	No	If utilizing vaporizer, does it meet NFPA 58:3-6?
Yes	No	Tank supported according to NFPA 58:3-4.2 through 58:3-2.4.9.
Yes	No	Means provided to minimize possibility of water/matter entering into relief device or any discharge piping.
Yes	No	Compliance with all applicable requirements, including but not limited to, emergency shutoff valve, backflow check valve, anchorage, breakaway, thermal release and remote shutoff control.
Yes	No	Protection against tampering according to NFPA 58:3-3.6.
Describe provisions for protection against tampering: _____		

If point of transfer is located at container, skip to next section.

Point of transfer	Horizontal distance
Nearest building	
Line of adjoining property which is or may be built upon	
Outdoor places of public assembly, including school yards, athletic fields, and playgrounds	
Public ways, including public streets, highways, thoroughfares, and sidewalks	
Mainline railroad track centerline	
Containers other than those being filled	
Flammable and combustible liquid dispensers/containers	

Submit the following in duplicate:

Diagram indicating location of tanks in relation to power lines, streets, property lines, buildings, and vaporizers.

Diagram describing point of transfer. (Bulkhead and emergency shutoff valves.)

CERTIFICATION

I certify by signature that all is in compliance with the most recent applicable provision of NFPA 58.

All information provided is accurate and current.

Signature: _____ Date: _____

PLEASE MAIL TO:

North Dakota Fire Marshal's Office
PO Box 1054
Bismarck, ND 58502-1054

Phone: (701) 328-5555

Or FAX: (701) 328-5510

h:\forms\checklist\LPG_Preinstallation.doc